

Building ID	Sample Date	Fixture Type	Sample Type	Concentration (ug/L)	Notes
Empire Elementary	10/5/17	S - Sink	First Draw	3.27	
Empire Elementary	10/5/17	S - Sink	Flush	< 2.00	
Empire Elementary	10/5/17	DF - Drinking Fountain	First Draw	< 2.00	
Empire Elementary	10/5/17	DF - Drinking Fountain	Flush	< 2.00	
Empire Elementary	10/5/17	DF - Drinking Fountain	First Draw	< 2.00	
Empire Elementary	10/5/17	DF - Drinking Fountain	Flush	< 2.00	
Empire Elementary	10/5/17	DF - Drinking Fountain	First Draw	< 2.00	
Empire Elementary	10/5/17	DF - Drinking Fountain	Flush	< 2.00	
Empire Elementary	10/5/17	DF - Drinking Fountain	First Draw	< 2.00	
Empire Elementary	10/5/17	DF - Drinking Fountain	Flush	< 2.00	
Empire Elementary	10/5/17	DF - Drinking Fountain	First Draw	4.62	disabled
Empire Elementary	10/5/17	DF - Drinking Fountain	Flush	5.91	disabled
Empire Elementary	10/5/17	DF - Drinking Fountain	First Draw	2.88	disabled
Empire Elementary	10/5/17	DF - Drinking Fountain	Flush	6.40	disabled
Empire Elementary	10/5/17	DF - Drinking Fountain	First Draw	< 2.00	
Empire Elementary	10/5/17	DF - Drinking Fountain	Flush	< 2.00	
Empire Elementary	10/5/17	DF - Drinking Fountain	First Draw	< 2.00	
Empire Elementary	10/5/17	DF - Drinking Fountain	Flush	< 2.00	
Empire Elementary	10/5/17	DF - Drinking Fountain	First Draw	< 2.00	
Empire Elementary	10/5/17	DF - Drinking Fountain	Flush	< 2.00	
Empire Elementary	10/5/17	DF - Drinking Fountain	First Draw	< 2.00	
Empire Elementary	10/5/17	DF - Drinking Fountain	Flush	< 2.00	